

Operator  
Telephone  
Fax  
e-Mail

## SloanLED Progressive Down Light 3 (100W) / UGR-Table

Luminaire: SloanLED Progressive Down Light 3 (100W)  
Lamps: 124 x LED

<b>Glare Evaluation According to UGR</b>											
$\rho$ Ceiling		70	70	50	50	30	70	70	50	50	30
$\rho$ Walls		50	30	50	30	30	50	30	50	30	30
$\rho$ Floor		20	20	20	20	20	20	20	20	20	20
Room Size X Y		Viewing direction at right angles to lamp axis					Viewing direction parallel to lamp axis				
2H	2H	31.2	32.4	31.5	32.7	32.9	31.2	32.4	31.5	32.7	32.9
	3H	31.8	32.9	32.2	33.2	33.4	31.8	32.9	32.2	33.2	33.4
	4H	32.0	33.0	32.3	33.3	33.6	32.0	33.0	32.3	33.3	33.6
	6H	32.1	33.0	32.4	33.3	33.6	32.1	33.0	32.4	33.3	33.6
	8H	32.1	33.0	32.4	33.3	33.6	32.1	33.0	32.4	33.3	33.6
	12H	32.1	32.9	32.4	33.2	33.6	32.1	32.9	32.4	33.2	33.6
4H	2H	31.6	32.6	31.9	32.9	33.2	31.6	32.6	31.9	32.9	33.2
	3H	32.3	33.2	32.7	33.5	33.8	32.3	33.2	32.7	33.5	33.8
	4H	32.5	33.3	32.9	33.6	34.0	32.5	33.3	32.9	33.6	34.0
	6H	32.7	33.3	33.1	33.7	34.1	32.7	33.3	33.1	33.7	34.1
	8H	32.7	33.3	33.1	33.7	34.1	32.7	33.3	33.1	33.7	34.1
	12H	32.7	33.2	33.1	33.6	34.1	32.7	33.2	33.1	33.6	34.1
8H	4H	32.6	33.2	33.0	33.6	34.0	32.6	33.2	33.0	33.6	34.0
	6H	32.8	33.3	33.2	33.7	34.1	32.8	33.3	33.2	33.7	34.1
	8H	32.8	33.2	33.3	33.7	34.2	32.8	33.2	33.3	33.7	34.2
	12H	32.9	33.2	33.3	33.7	34.2	32.9	33.2	33.3	33.7	34.2
12H	4H	32.6	33.1	33.0	33.5	34.0	32.6	33.1	33.0	33.5	34.0
	6H	32.8	33.2	33.2	33.6	34.1	32.8	33.2	33.2	33.6	34.1
	8H	32.8	33.2	33.3	33.7	34.2	32.8	33.2	33.3	33.7	34.2
Variation of the observer position for the luminaire distances S											
S = 1.0H		+0.3 / -0.4					+0.3 / -0.4				
S = 1.5H		+0.7 / -1.2					+0.7 / -1.2				
S = 2.0H		+1.5 / -2.2					+1.5 / -2.2				
Standard table		BK02					BK02				
Correction Summand		14.8					14.8				
Corrected Glare Indices referring to 10892lm Total Luminous Flux											

The UGR values have been calculated according to CIE Publ. 117 Spacing-to-Height-Ratio = 0.25.