

KLV-AOT8-120-A test by KLV Ledverlichting





Summary measurement data


parameter	meas. result	remark	
Color	5433 K	Cold white	
temperature			
Luminous	417 Cd	Measured straight underneath the lamp	
intensity I _v			
Illuminance	44 %	Measured straight underneath the lamp. Is a	
modulation		measure for the amount of flickering.	
index			
Beam angle	139 deg	139° for the C0-C180 plane (crossing length	
		direction of the tube) and 115° for the C90-C270	
		plane (length direction).	
Power P	20.9 W		
Power Factor	0.96	For every 1 kWh net power consumed, there has	
		been 0.3 kVAhr for reactive power.	
THD	11 %	Total Harmonic Distortion	
Luminous	1589 Lm		
flux			
Luminous	76 Lm/W		
efficacy			
CRI_Ra	70	Color Rendering Index.	
Coordinates	x=0.3346 and		
chromaticity	y=0.3564		
diagram			
Fitting	FL-tube	This Tube Light is connected directly to the grid	
		voltage of 230 V AC.	
PAR-value	3.6 µMol/s/m²	The number of photons seen by an average plant	
		when it is lit by the light of this light bulb. Value	
		valid at 1 m distance from light bulb.	
PAR-photon	0.6 µMol/s/W _e	The toal emitted number of photons by this light,	
efficacy		divided by its consumption in W. It indicates a	
		kind of efficacy in generating photons.	



S/P ratio	1.8	This factor indicates the amount of times more efficient the light of this light bulb is perceived under scotopic circumstances (low environmental light level).	
L x D external dimensions	1197 x 31 mm	External dimensions of the luminaire.	
LxWxH	1160 x 31 x 16	Dimensions of the luminous area (used in	
luminous	mm	Eulumdat file). This is equal to the dimensions of	
area		the matte cover. In the C0-C180 direction also its	
		height is visible.	
General		The ambient temperature during the whole set of	
remarks		measurements was 22.2-22.8 deg C.	
		The hottest temperature of the luminaire is	
		about 25 degrees hotter than ambient.	
		Warm up effect: during the warm up time the	
		illuminance decreases with about 9 % and the	
		consumed power with about 8%.	
		Voltage dependency: the power consumption and	
		illuminance do not depend significantly when the	
		voltage is varied from 200 - 250 V.	



Overview table




The overview table is explained on the OliNo website.

Please note that this overview table makes use of calculations, use this data with care as explained on the OliNo site. E (lux) values are not accurate, when within 5 x 1160 mm \approx 5800 mm. Within this distance from the lamp, the measured lux values will be less than the computed values in this overview as the measurements are then within the near field of the lamp.

Eulumdat light diagram

This light diagram below comes from the program Qlumedit, that extracts these diagrams from an Eulumdat file. It is explained on the OliNo site.






The light diagram giving the radiation pattern.

It indicates the luminous intensity around the light bulb. The direction or plane C0-C180 cuts the lamp in the direction crossing the length direction of the tube, and the C90-C270 plane cuts the lamp in the length direction.

Illuminance Ev at 1 m distance, or luminous intensity Iv

Herewith the plot of the *averaged* luminous intensity Iv as a function of the inclination angle with the light bulb.






The radiation pattern of the light bulb.

This radiation pattern is the average of the light output of the light diagram given earlier. Also, in this graph the luminous intensity is given in Cd. These averaged values are used (later) to compute the lumen output.





Intensity data of every measured turn angle at each inclination angle.

This plot shows per inclination angle the intensity measurement results for each turn angle at that inclination angle. There normally are differences in illuminance values for different turn angles. However for further calculations the averaged values will be used. When using the average values per inclination angle, the beam angle can be computed, being 139° in the C0-C180 plane and 115° in the C90-C270 plane.

Luminous flux

With the averaged illuminance data at 1 m distance, taken from the graph showing the averaged radiation pattern, it is possible to compute the luminous flux. The result of this computation for this light spot is a luminous flux of 1502 Lm.

Luminous efficacy

The luminous flux being 1589 Lm, and the power of the light bulb being 20.9 W, yields a luminous efficacy of 76 Lm/W.




Electrical properties

A power factor of 0.96 means that for every 1 kWh net power consumed, a reactive component of 0.3 kVAr was needed.

Lamp voltage	230 VAC
Lamp current	94 mA
Power P	20.9 W
Apparent power S	21.7 VA
Power factor	0.96


Of this light bulb the voltage across ad the resulting current through it are measured and graphed. See the OliNo site how this is obtained.



Voltage across and current through the lightbulb

This waveforms have been checked on requirements posed by the norm IEC 61000-3-2:2006 (including up to A2:2009). See also the explanation on the OliNo website.






Harmonics in in the current waveform and checked against IEC61000-3-2:2006

There are no limits for the harmonics for lighting equipment <= 25 W. The Total Harmonic Distortion of the current is computed as 11 %.




Temperature measurements lamp



Emissivity comparison.


The emissivity of the tube housing is very much the same as that of the tape, being around 0.95.





One end of the tube.





The other end of the tube.


For the temperature measurement a piece of masking tape was used and found that the aluminum material has an almost equally high emissivity (of 0.95).

status lamp	> 2 hours on
ambient temperature	23 deg C
reflected background temperature	23 deg C
camera	Flir T335
emissivity	0.95(1)
measurement distance	1.0 m
IFOV _{geometric}	1.4 mm
NETD (thermal sensitivity)	50 mK

⁽¹⁾ See the images and text for explanation.



Color temperature and Spectral power distribution




The spectral power distribution of this light bulb, energies on y-axis valid at 1 m distance.

The measured color temperature is about 5425 K which is cold white.

This color temperature is measured straight underneath the light bulb. Below a graph showing the color temperature for different inclination angles.





Color temperature as a function of inclination angle.


The measurement of CCT is measured for inclination angles up to 80° as beyond that angle the illuminance values are very low (< 5 lux).

The beam angle is maximally 139° , meaning a 69.5° inclination angle. In this area most of the light is present. The variation in correlated color temperature in this area is about 2%.



PAR value and PAR spectrum

To make a statement how well the light of this light bulb is for growing plants, the PAR-area needs to be determined. See the OliNo website how this all is determined and the explanation of the graph.



The photon spectrum, then the sensitivity curve and as result the final PAR spectrum of the light of this light bulb


parameter	value	unit
PAR-number	3.6	μMol/s/m²
PAR-photon current	13.5	μMol/s
PAR-photon efficacy	0.6	μMol/s/W

The PAR efficiency is 64% (valid for the PAR wave length range of 400 - 700 nm). So maximally 64% of the total of photons in the light is effectively used by the average plant (since the plant might not take 100% of the photons at the frequency where its relative sensitivity is 100%).



S/P ratio

The S/P ratio and measurement is explained on the OliNo website. Here the results are given.




The power spectrum, sensitivity curves and resulting scotopic and photopic spectra (spectra energy content defined at 1 m distance).

The S/P ratio is 1.8.

More info on S/P ratio can be found on the OliNo website.



Chromaticity diagram




The chromaticity space and the position of the lamp's color coordinates in it.

The light coming from this lamp is inside the area designated with class A. This Class A is an area that is defined for signal lamps, see also the OliNo website. Its coordinates are x=0.3346 and y=0.3564.



Color Rendering Index (CRI) or also Ra

Herewith the image showing the CRI as well as how well different colors are represented (rendered). The higher the number, the better the resemblance with the color when a black body radiator would have been used (the sun, or an incandescent lamp). Practical information and also some critics about the CRI can be found on the OliNo website. Each color has an index Rx, and the first 8 indexes (R1 .. R8) are averaged to compute the Ra which is equivalent to the CRI.



CRI of the light of this lightbulb.


The value of 70 is lower than 80 which is considered a minimum value for indoor usage. Note: the chromaticity difference is 0.0037 indicates the distance to the Planckian Locus. There is no norm yet that states what the max deviation from white light is allowed to be. A reference with signal lights as a reference is given in the chromaticity diagram.

Voltage dependency

The dependency of a number of lamp parameters on the lamp voltage is determined. For this, the lamp voltage has been varied and its effect on the following light bulb parameters measured: illuminance $E_v[lx]$, the lamppower P[W] and the luminous



efficacy [Lm/W].



Lamp voltage dependencies of certain light bulb parameters, where the value at 230 V is taken as 100 %.


The illuminance and consumed power do not vary significantly when the voltage is varied.

When the voltage at 230 V varies with + and - 5 V, then the illuminance varies \approx 0.1 %, so when abrupt voltage changes occur this effect is not visible in the illuminance output.

Warm up effects

After switch on of a cold lamp, the effect of heating up of the lamp is measured on illuminance E_v [lx], the lamppower P [W] and the luminous efficacy [lm/W].






Effect of warming up on different light bulb parameters. At top the 100 % level is put at begin, and at bottom at the end.



The warm up time is about 30 minutes. During that time the illuminance decreases with about 9% and the consumed power with about 8%.

Measure of flickering

An analysis is done on the measure of flickering of the light output by this light bulb. See the OliNo site for more information.



The measure of fast illuminance variantion of the light of the light bulb

parameter	value	unit
Flicker frequency	100	Hz
Illuminance modulation index	44	%

The illuminance modulation index is computed as: (max_Ev - min_Ev) / (max_Ev + min_Ev).

Disclaimer

The information in this OliNo report is created with the utmost care. Despite this, the information could contain inaccuracies. OliNo cannot be held liable in this instance nor can the data in this



report be legally binding.

License

It is permitted ONLY to use or publish this report in its entirety and in unaltered form via internet or other digital or written media in any form. To guarantee the reliability and accuracy of the report, it is strictly probited to change or alter parts of the report and/or republish it in a modified content.